FILE; Accum

A34003

PA 30-A
8-63

MEMORANDUM

F-30

REFER		NOTED	
TO	DATE	BY	DATE
RETURN TO		FILE	

TO: Mr. F. H. Wernecke, Assistant Construction Manager - WTC
FROM: A. J. Calabrese
DATE: July 24, 1968
SUBJECT: WORLD TRADE CENTER - Inspection of Fire-proofing

REFERENCE:

COPY TO: Messrs. Druding, Magrath; File

TISHMAN
JUL 26 1968
CONSTRUCTION DEPT.

I inspected the Cafco spray material applied by Mc Dermott and D'Bono on January 29, 1968 and on this date, July 22, 1968 and found no signs of dusting or peeling of material from the steel.

Material exposed to weather during above time.

A. J. Calabrese
Construction Inspector
World Trade Center

AJC:gb

PLAINTIFF'S EXHIBIT
PX-493

Gustman